

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**

**LISTING No.** 6200-1639:100

Page 1 of 1

**CATEGORY:** Exit Signs

**LISTEE:** LUNA Technologies International Inc., 19226-70<sup>th</sup> Ave, Kent, WA 98032  
Contact: Kimberly Landry (888) 955-8883 FAX (888) 955-6688

**DESIGN:** LUNApast 5000 Sun Series photoluminescent exit signs. These sign placards with a photoluminescent background use PVC impregnated with strontium oxide aluminate pigment and opaque letters spelling the word 'EXIT'. Opaque directional indicators are optional included at one or both sides of the EXIT legend. The substrate material is semi-rigid PVC provided with holes for mechanical mounting to a surface. Refer to the listee's data sheet for detailed product description and operational considerations.

**RATING:** \*90 minutes  
Legible viewing distance is 75 feet.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

**MARKING:** Listee's name, model number, rating/legible viewing distance, and UL label.

**APPROVAL:** Listed as photoluminescent exit signs for use where permitted by code and only in locations where a minimum 5 foot-candle external unfiltered fluorescent illumination source is present on the sign face, is deemed reliable and is supplied by a circuit not controlled by automatic timers or sensors, and whose controls are accessible only to authorized personnel. This reliable external illumination source is to be energized at all times of building occupancy. Refer to listee's Installation Instruction Manual for details. Authority having jurisdiction should be consulted prior to installation.

\*Corrected 12-14-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 14, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager